

ADDENDUM NO. 2 *Damen King*

In reference to the previously issued Request for Proposal documents for the subject item, the changes and additions listed below are to be incorporated. All other conditions remain the same.

Receipt of this Addendum shall be acknowledged by inserting the number two (2) in the “Acknowledgement receipt of addenda number...(if any)” area on the Bid Proposal form.

SPECIFICATIONS

Section 07511 Built-up Asphalt Roofing, Paragraph 2.1.A.1.a.;
Change to read: Karnack 98AF Fibrated Aluminum roof coating.

Section 07511 Built-up Asphalt Roofing, Paragraph 2.2.A;
Change to read: Roof Coating ASTM D 2824 Type III, (non asbestos) fibrated aluminum roof coating

Section 07511 Built up Asphalt Roofing, Paragraph 3.3.B;
Change to read: Apply at the rate of 1 ½ gallons per 100 square feet.

DRAWINGS

Sheet A2.4, McDonald Elementary
Add: Plan work note #4: Provide new pitch pocket for four electrical and condensate line penetrations on lower roof.

END OF ADDENDUM #2